



# MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890  
1411 S. 12th St. ~ Bismarck, ND 58502 ~ 800-279-6885 ~ Fax 701-258-9724  
35 W. Lincoln Way ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885  
www.mvtl.com



Sample Number: 07-F111

Report Date: 2/13/07

Jim Brown  
Atlas Marketing  
16620 Prairie Ave.  
Hauser ID 83854

Work Order #: 81-193  
P.O. #: Jim Brown

Date Received: 2/12/07

Sample Description: Pellet Sample

### \*PROXIMATE\*

ANALYTE	AS RECEIVED		DRY BASIS	
Total Moisture	5.00	wt. %		
Ash	0.07	wt. %	0.07	wt. %
Total Sulfur	0.03	wt. %	0.03	wt. %
Calorific Value BTU/lb	8170	BTU/lb	8600	BTU/lb

Approved By: \_\_\_\_\_

*D. Zander*

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.